

♦ Water Analysis

◆ Food/Seafood Analysis

◆ Metals/Chemical Analysis

→ Microbiological Testing

246 Arlington Street, Quincy, MA 02170 Email: info@gllab.com Tel: (617) 328-3663 Fax: (617) 472-0706 www.GLlab.com

Lab ID. # 103197

To: Attn: Mr. Kevin Ryder
Parks & Recreation Dept.
Town of Medfield
124 North St.
Medfield, MA 02052

Received Date/Time:	6/29/22, 5:45 PM	
Analyzed Date/Time:	6/29/22, 5:53 PM	
Reported Date:	6/30/22	
Collected By:	G & L Labs	
Collection Date:	6/29/22	

ANALYTICAL RESULTS

Sample#	Sampling Location	Sampling Time	E. coli (CFU/100mL)	Geomean
1	Hinkley Swim Pond - Left Side	4:38 PM	<5	
2	Hinkley Swim Pond - Right Side	4:40 PM	<5	
Maximum Contaminant Level		235	126	
Method of Reference		EPA 1603	137 (157)	

Laboratory QC Results

QC	Unit	E. coli
Duplicate (D1)	100mL	< 5
Duplicate (D2)	100mL	<5
Dilution Blk.(Beginning)	100mL	Negative
Dilution Blk.(Ending)	100mL	Negative
Positive Control	100mL	Positive

CC: Medfield BOH

Approved By:

Lab. Director

Date